

Acoustic Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Product Description DUPLEX-RISER-120

Test Reference BTC 17782A

Date 7th June 2012

Report Number H17782DA

Methodology Laboratory Measurement to BS EN ISO 717-1:1997

Acoustic Reduction 36dB
(f, Hz 100-3150)


Test Centre The Building Test Centre
British Gypsum
East Leake
Loughborough
Leics. LE12 6NP
Tel (0115) 945 1564
Fax (0115) 945 1562
email btc.testing@saint-gobain.com

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723



This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.

This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.

The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

The original documents are intellectual property of the Access Building Products Ltd.

