

Smoke Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Product Description HA 560

Test Reference WYC 389347/08

Date 2nd September 2017

Methodology Laboratory Measurement to BS EN 1634-3: 2004

Leakage Rate
(25Pa)

Positive Chamber (m³/m/h)
2.66

Negative Chamber (m³/m/h)
1.92

Test Centre

Exova
Chiltern House
Stocking Lane
Hughenden Valley
High Wycombe
Buckinghamshire
HP14 4ND
Tel (0192) 565 5116
email cathryn.cooper@bmtrada.com

Access Building Products Ltd

Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.

This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.

The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

The original documents are intellectual property of the Access Building Products Ltd.

