

Notified body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of Constancy of Performance

1121 - CPR – ABB035

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

“Escape Locks and Lever Handle Range” Emergency Exit Device

Intended use:- For use on single leaf escape route doors, including fire resisting / smoke control doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence : 182145 / 186078 / 321007 / 326041 / 340592 / 349295 & 355726 Fire Test Evidence : Warres C113746 Iss 5 / 136725 Iss 3 & 163416	
Clause 4.2.1 Ability to release (for doors on escape routes) Release function Lever handle Single doorset Double doorset Exposed edges and corners Lever handle installation Operating element projection Operating element face (Lever handle) Lever handle operating gap Test rod Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass Pass NPD Pass X >120mm & Z < 150mm W < 100mm V > 18mm / free end U > 40mm / W < 100mm, a < 30° Pass Pass Pass Pass NPD Pass NPD Door mass ≤ 200 Kg, door height ≤ 2500 mm, door width ≤ 1300 mm Pass Type A < 70 N Grade 4	EN 179:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes) Corrosion resistance Temperature range Lubrication Re-engagement force Durability Abuse resistance –lever handle Final examination	Grade 3 : 96 hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N Type A < 70 N	

Certificate of Constancy of Performance

1121 - CPR – ABB035

Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50 N	
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50 N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on escape routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies –	Grade B: Suitable for use on fire/smoke single door assemblies.	
Additional requirements		
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Certificate of Constancy of Performance

1121 - CPR – ABB035

Lever reference	Lock reference 7178F60 7178F80 7278F60 7278F80 7278.60 7278.80	Lock reference 7181F60 7181F80 7281F60 7281F80 7281.60 7281.80	Lock reference 7182F60 7282F60	Lock reference 9990P 9941P * 9942P * 9945P * 9946P * 9970P 9962HDP 9971HBP
MA3502D	✓	✓	✓	✓
SS3502D	✓	✓	✓	✓
PS3502D	✓	✓	✓	✓
PB3502D	✓	✓	✓	✓
MA3506D	✓	✓	✓	✓
SS3506D	✓	✓	✓	✓
PS3506D	✓	✓	✓	✓
PB3506D	✓	✓	✓	✓
3510	✓	✓	✓	✓
97442	✓	✓	✓	✓

For use on single door applications

* Locks 9941P, 9942P, 9945P and 9946P are solenoid activated for the outside lever handle only.

Single sided half spindle 9052NT, Through split spindles 9069N, 9069T, 9070N and 9070T can be used with above lever furniture and locks to suit the door application required.

Certificate of Constancy of Performance

1121 - CPR – ABB035

Produced for

ALLGOOD PLC
297 Eustone Road, London
NW1 3AQ

and produced in the manufacturing plant

E/011 & E/013

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 179: 2008

Under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **10/12/15** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
Certification Manager
Warrington Certification Ltd

