

Icopal Limited

Barton Dock Road
Stretford
Manchester M32 0YL
Tel: 0161-865 4444 Fax: 0161-864 8433
e-mail: market.uk@icopal.com
website: www.icopal.co.uk



Agrément Certificate
12/4962
Product Sheet 2

SUREPLAN FPO MEMBRANES

SUREPLAN FPO FULLY ADHERED ROOF WATERPROOFING MEMBRANES

This Agrément Certificate Product Sheet⁽¹⁾ relates to Sureplan FPO Fully Adhered Roof Waterproofing Membranes, glass reinforced FPO roofing sheets with a non-woven polyester fleece backing for use as bonded waterproofing on flat and pitched roofs with limited access.

(1) Hereinafter referred to as 'Certificate'.

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness — the membranes will resist the passage of moisture into the building (see section 6).

Properties in relation to fire — the membranes will enable a roof to be unrestricted under the Building Regulations (see section 7).

Resistance to wind uplift — the membranes will resist the effects of any likely wind suction acting on the roof (see section 8).

Resistance to foot traffic — the membranes will accept the limited foot traffic and loads associated with installation and maintenance (see section 9).

Durability — under normal service conditions the membranes will provide a durable roof waterproofing with a service life in excess of 20 years (see section 11).

The BBA has awarded this Certificate to the company named above for the products described herein. These products have been assessed by the BBA as being fit for their intended use provided they are installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Simon Wroe
Head of Approvals — Materials

Greg Cooper
Chief Executive

Date of First issue: 3 April 2013

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Watford
Herts WD25 9BA

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk

©2013

Regulations

In the opinion of the BBA, Sureplan FPO Fully Adhered Roof Waterproofing Membranes, if installed, used and maintained in accordance with this Certificate, will meet or contribute to meeting the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement:	B4(2)	External fire spread
Comment:		On suitable substructures the use of the membranes will enable a roof to be unrestricted under this Requirements. See section 7 of this Certificate.
Requirement:	C2(b)	Resistance to moisture
Comment:		The membranes, including joints, will enable a roof to meet this Requirement. See section 6.1 of this Certificate.
Regulation:	7	Materials and workmanship
Comment:		The membranes are acceptable. See section 11 and the <i>Installation</i> part of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation:	8(1)(2)	Fitness and durability of materials and workmanship
Comment:		Use of the membranes satisfies the requirements of this Regulation. See sections 10, 11 and the <i>Installation</i> part of this Certificate.
Regulation:	9	Building standards applicable to construction
Standard:	2.8	Spread from neighbouring buildings
Comment:		The membranes, when applied to a suitable substructure, are regarded as having low vulnerability under clause 2.8.1 ⁽¹⁾⁽²⁾ of this Standard. See section 7 of this Certificate.
Standard:	3.10	Precipitation
Comment:		The membranes, including joints, will enable a roof to satisfy the requirements of this Standard, with reference to clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.7 ⁽¹⁾⁽²⁾ . See section 6.1 of this Certificate.
Standard:	7.1(a)	Statement of sustainability
Comment:		The membranes can contribute to meeting the relevant requirements of Regulation 9, Standards 1 to 6 and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard.
Regulation:	12	Building standards applicable to conversions
Comment:		All comments given for these membranes under Regulation 9, Standards 1 to 6 also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012

Regulation:	23(a)(i)(iii)(b)(i)	Fitness of materials and workmanship
Comment:		The membranes are acceptable. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation:	28(b)	Resistance to moisture and weather
Comment:		The membranes, including joints, will enable a roof to satisfy the requirements of this Regulation. See section 6.1 of this Certificate.
Regulation:	36(b)	External fire spread
Comment:		On suitable substructures the use of the membranes will be unrestricted by the requirements of this Regulation. See section 7 of this Certificate.

Construction (Design and Management) Regulations 2007

Construction (Design and Management) Regulations (Northern Ireland) 2007

Information in this Certificate may assist the client, CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

See sections: 1 *Description* (1.2) and 3 *Delivery and site handling* (3.3) of this Certificate.

Additional Information

NHBC Standards 2013

NHBC accepts the use of Sureplan FPO Fully Adhered Roof Waterproofing Membranes, provided they are installed, used and maintained in accordance with this Certificate, in relation to *NHBC Standards, Chapter 7.1 Flat roofs and balconies*.

CE marking

The Certificate holder has taken the responsibility of CE marking the products in accordance with harmonised European Standard EN 13956 : 2005. An asterisk (*) appearing in this Certificate indicates that data shown is given in the manufacturer's Declaration of Performance.

Technical Specification

1 Description

1.1 Sureplan FPO Fully Adhered Roof Waterproofing Membranes are glass reinforced, flexible polyolefin (FPO) roofing sheets with a non-woven polyester fleece backing. They are available in two grades; Sureplan FPO Fleeceback Membrane and Sureplan FPO Plus Fleeceback Membrane, an enhanced fire performance grade.

1.2 The membranes are manufactured to the following nominal parameters:

Thickness* (mm)	1.5
Width* (m)	2.12
Length* (m)	15
Mass per unit area* (kg·m ⁻²)	
Standard	2.02
Plus	2.29
Tensile strength* (N per 50 mm)	
longitudinal direction	≥ 1100
transverse direction	≥ 1000
Tear strength* (N)	≤ 125
Nail tear strength (N)	≤ 250
Low temperature foldability (°C)	≤ -40.

1.3 Ancillary items necessary for installation of the membranes and included in this assessment are:

- Sureplan Detailing Membrane — an unreinforced flashing membrane for detailing
- Sureplan Coated Metal — FPO compound coated material sections for use at perimeter details and similar detailing
- Icopal Single-ply Fleeceback Adhesive — a polyurethane adhesive, for use in bonding the membrane to the substrate
- Sureplan internal corners and external corners — FPO prefabricated corner details.

1.4 Other items or components which may be used with the membranes, but which are outside of the scope of this Certificate are:

- Icopal TPO Contact Adhesive — a contact adhesive for use in detailing of the membrane
- Sureplan Walkway — an FPO membrane with a non-slip surface for maintenance traffic
- standing seam profile — used to create architectural features on pitched roofs
- rainwater outlets — FPO finishing elements to detail at water drainage points
- pipe flashings — FPO prefabricated details for roof penetrations
- lightning conductor pads.

2 Manufacture

2.1 The membrane is manufactured by a two pass extrusion coating process of the glassfibre reinforcement with the fleece laminated to the underside of the membrane.

2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:

- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

3 Delivery and site handling

3.1 The membranes are delivered to site in rolls wrapped in polythene on pallets with labels bearing the manufacturer's name and address, product identification, dimensions, batch number and the BBA identification mark incorporating the number of this Certificate.

3.2 Rolls should be stored on their side, on a clean, level surface, and kept under cover.

3.3 Icopal Single-ply Fleeceback Adhesive and Icopal TPO Contact Adhesive are classified under *The Chemicals (Hazard Information and Packaging for Supply) Regulations 2009 (CHIP4)/Classification, Labelling and Packaging of Substances and Mixtures (CLP Regulation) 2009*. The classifications are given in Table 1. These products bear the appropriate hazard warning.

Table 1 Flashpoint and hazard classification

Materials	Flashpoint (°C)	Classification
Icopal Single-ply Fleeceback Adhesive	N/A	Harmful
Icopal TPO Contact Adhesive	-18 ⁽¹⁾	Harmful, Highly flammable, Dangerous for the environment

(1) This component must be stored in accordance with *The Dangerous Substances and Explosive Atmospheres Regulations 2002*.

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Sureplan FPO Fully Adhered Roof Waterproofing Membranes.

Design Considerations

4 General

4.1 Sureplan FPO Fully Adhered Roof Waterproofing Membranes are satisfactory for use as a fully bonded waterproofing system on flat and pitched roofs with limited access.

4.2 Limited access roofs are defined for the purpose of this Certificate as those roofs subjected only to pedestrian traffic for maintenance of the roof covering and cleaning of gutters, etc. Where traffic in excess of this is envisaged, additional protection to the membrane must be provided (see section 9).

4.3 Flat roofs are defined for the purpose of this Certificate as those roofs having a minimum finished fall of 1:80. For design purposes, twice the minimum finished fall should be assumed, unless a detailed analysis of the roof is available, including overall and local deflection, direction of falls, etc. Pitched roofs are defined for the purpose of this Certificate as those having a fall greater than 1:6.

4.4 Decks to which the products are to be applied must comply with the relevant requirements of BS 6229 : 2003, BS 8217 : 2005 and, where appropriate, *NHBC Standards 2013*, Chapter 7.1.

4.5 Insulation materials to be used in conjunction with the membranes must be in accordance with the Certificate holder's instructions and be either:

- as described in the relevant Clauses of BS 8217 : 2005, or
- the subject of a current BBA Certificate and be used in accordance with that Certificate.

5 Practicability of installation

Installation of the membranes must be carried out only by installers trained and approved by the Certificate holder.

6 Weathertightness

6.1 The membranes, including joints, when completely sealed and consolidated will adequately resist the passage of moisture into the building and enable a roof to comply with the requirements of the national Building Regulations:

England and Wales — Approved Document C, Requirement C2(b), Section 6

Scotland — Mandatory Standard 3.10, clauses 3.10.1 and 3.10.7

Northern Ireland — Regulation 28(b).

6.2 The membranes are impervious to water and will achieve a weathertight roof capable of accepting minor structural movement.

7 Properties in relation to fire

7.1 Results of tests indicate the following systems are classified under BS EN 13501-5 : 2005 as B_{ROOF} (t4):

- a primed 18 mm plywood substrate, a fully bonded modified bitumen vapour control layer, a 90 mm thick, glass tissue faced polyisocyanurate insulation board bonded to the VCL using a polyurethane adhesive and the 1.2 mm⁽¹⁾ version of the Sureplan FPO Plus Fleeceback Membrane fully bonded using Icopal Single-ply Fleeceback Adhesive
- a primed 18 mm plywood substrate, a fully bonded modified bitumen vapour control layer, a 90 mm thick, glass tissue faced polyisocyanurate insulation board bonded to the VCL using a polyurethane adhesive and the 1.2 mm⁽¹⁾ version of the Sureplan FPO Fleeceback Membrane fully bonded using Icopal Single-ply Fleeceback Adhesive.

(1) Indicative testing on the thicker membranes indicates that, when used in the same specification as the 1.2 mm membrane, they will be unrestricted under the Regulations.

7.2 The designation of other specifications must be confirmed by:

England and Wales — test or assessment in accordance with Approved Document B, Appendix A, clause 1

Scotland — test to conform to Mandatory Standard 2.8, clause 2.8.1

Northern Ireland — test or assessment by a UKAS accredited laboratory, or an independent consultant with appropriate experience.

8 Resistance to wind uplift

8.1 When the membranes are fully adhered to a suitable substrate, the bond is sufficient to resist the effect of wind suction, thermal cycling or other minor structural movements likely to occur in service.

8.2 When the membranes are bonded to insulation boards, the resistance to wind uplift will be dependent on the cohesive strength of the insulation and the method by which it is secured to the roof deck. This must be taken into account when selecting suitable insulation material.

9 Resistance to foot traffic

Results of tests indicate that the membranes can accept the limited foot traffic and light concentrated loads associated with installation and maintenance. Reasonable care should be taken to avoid puncture by sharp objects or concentrated loads. Where traffic in excess of this is envisaged, such as maintenance of lift equipment, a walkway should be provided, for example, using concrete slabs supported on bearing pads or the Sureplan Walkway.

10 Maintenance



10.1 Systems must be the subject of annual inspections and maintenance to ensure continued performance. Exposed membrane must be free from the build-up of silt and other debris and unwanted vegetation must be cleared.

10.2 Where damage has occurred, it should be repaired in accordance with section 16 and the Certificate holder's instructions.

11 Durability



Accelerated weathering tests and evidence from existing installations confirm that satisfactory retention of physical properties is achieved. Under normal conditions, the products will have a service life in excess of 20 years.

12 Reuse and recyclability

The products comprise thermoplastic polyolefin and glass, which can be recycled.

Installation

13 General

13.1 Installation of Sureplan FPO Fully Adhered Roof Waterproofing Membranes must be carried out in accordance with the relevant clauses of the Certificate holder's instructions, BS 8000-4 : 1989 and this Certificate.

13.2 Conditions on site should be those for normal roof waterproofing work. Deck surfaces must be dry, clean and free from sharp projections such as nail heads and concrete nibs. When used over a rough substrate, a suitable protection layer must be placed over the substrate.

13.3 Installation should not be carried out during wet weather (eg rain, fog, snow) nor when the temperature is below 0°C unless suitable precautions against surface condensation are taken in accordance with the Certificate holder's instructions.

13.4 Details are formed in accordance with the Certificate holder's instructions.

14 Procedure

14.1 The membranes are unrolled onto the substrate without undulations, with 75 mm minimum side laps and end laps being butt joined and strapped.

14.2 The membrane is rolled half back and Icopal Single-ply Fleeceback Adhesive applied to the substrate at a rate of approximately 2.0 to 3.0 m²·kg⁻¹ and spread with a suitable squeegee followed by a roller to ensure an even distribution. The membrane is immediately unrolled into the wet adhesive. Care must be taken to smooth the surface of the membrane to avoid any creases or trapped air. This is repeated for the other half of the roll.

14.3 The membrane is rolled with a weighted roller immediately after application and then at intervals of 15 minutes until 45 minutes have elapsed, to ensure a complete bond.

14.4 The lap area must be dry and clean. If the membrane in the weld area has become contaminated, it must be cleaned in accordance with the Certificate holder's instructions.

14.5 Details at perimeter upstands should be either fully adhered or mechanically fixed.

15 Jointing

15.1 Joints are made using either automatic or hand-operated machines with the temperature set in accordance with the Certificate holder's instructions.

15.2 The lap area must be dry and clean. If the membrane in the weld area has become contaminated, it must be cleaned in accordance with the Certificate holder's instructions.

15.3 The welded width of the joint must be a minimum of 40 mm for field welds and detailing. Care must be taken to ensure that overheating of the membrane does not occur, as possible impairment of the membrane may result.

15.4 The seam is tested with a metal probe to highlight poorly-welded areas. Any such areas must be made good using hot-air welding.

16 Repair

In the event of damage occurring, repairs must be carried out by cleaning around the damaged area and applying a patch of the appropriate membrane in accordance with the Certificate holder's instructions.

Technical Investigations

17 Tests

17.1 An assessment was made of data to EN 13956 : 2005 in relation to:

- thickness
- width
- watertightness
- tear resistance
- dimensional stability
- shear resistance of joints
- mass per unit area
- flatness and straightness
- tensile strength
- dynamic indentation
- low temperature foldability
- water vapour diffusion (equivalent air layer thickness).
- length
- visible defects
- elongation at break
- static indentation
- peel resistance of joint

17.2 Tests were carried out to determine:

- nail tear
- resistance to heat ageing
- resistance to bitumen exposure
- resistance to exposure to water
- resistance to UV ageing
- resistance to wind uplift

in order to assess:

- robustness in service
- durability
- effect of wind loading.

18 Investigations

Data on fire performance of the membranes were assessed.

Bibliography

BS 6229 : 2003 *Flat roofs with continuously supported coverings — Code of practice*

BS 8000-4 : 1989 *Workmanship on building sites — Code of practice for waterproofing*

BS 8217 : 2005 *Reinforced bitumen membranes for roofing — Code of practice*

BS EN 13501-5 : 2005 *Fire classification of construction products and building elements — Classification using data from external fire exposure to roof tests*

EN 13956 : 2005 *Flexible sheet for waterproofing — Plastic and rubber sheets for roof waterproofing — Definitions and Characteristics*

19 Conditions

19.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page — no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective;
- is copyright of the BBA
- is subject to English Law.

19.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

19.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

19.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

19.5 In issuing this Certificate, the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance;
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal.
- any claims by the manufacturer relating to CE marking.

19.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.