

CRANE

FLUID SYSTEMS

NACTON ROAD

IPSWICH

SUFFOLK

IP3 9QH

DECLARATION OF CONFORMITY
The Pressure Equipment Directive 97/23/EC
The Pressure Equipment Regulations 1999 No. 2001

Reference No: D151A_D237A/001

Description of Pressure Equipment:

Brass Gate Valves – 8, 10, 15, 20, 25, 32, 40, 50, 65 and 80mm – Rated PN20

Service Limitations:

For use on Group 2 Gases and Group 1 & 2 Liquids

Conformity Assessment Procedure Followed:

8 – 50mm	Article 3 Para 3 (Sound Engineering Practice)
65 – 100mm	Module A

Name and Address of the Notified Body monitoring the Manufacturers Quality System:


British Standards Institution
Maylands Avenue
Hemel Hempstead
Hertfordshire
HP2 4SQ

References to Harmonised Standards used

References to other Technical Standards and Specifications used

<i>BS21 1985</i>	<i>ANSI B1.20.1 1983</i>	<i>BS6755 Part 1 1986</i>	
<i>BS5154 1985</i>	<i>BS EN 12165 CW602N 1998</i>	<i>PMS611</i>	<i>PMA07</i>

Authorised on behalf of Crane Fluid Systems

Name: I Wilson
Title: Engineering and Quality Director
Signature: 
Date: 02.02.02