

CRANE

FLUID SYSTEMS

NACTON ROAD

IPSWICH

SUFFOLK

IP3 9QH

DECLARATION OF CONFORMITY
(The Pressure Equipment Directive 97/23/EC)

Reference No: D159_D235/001

Description of Pressure Equipment:

Bronze Gate Valves – 8, 10, 15, 20, 25, 32, 40, 50, 65 and 80mm – Rated PN32

Service Limitations:

For use on Group 2 Gases and Group 1 & 2 Liquids

Conformity Assessment Procedure Followed:

8 – 32mm	Article 3 Para 3 (Sound Engineering Practice)
40 & 50mm	Module A
65 & 80mm	Module E1

Name and Address of the Notified Body monitoring the Manufacturers Quality System:

British Standards Institution
Maylands Avenue
Hemel Hempstead
Hertfordshire
HP2 4SQ

References to Harmonised Standards used

BS EN 1982 (CC491K)

References to other Technical Standards and Specifications used

BS21 1985 ANSI B1.20.1 1983 BS6755 Part 1 1986


BS5154 1985

Authorised on behalf of Crane Fluid Systems

Name: I Wilson

Title: Engineering and Quality Director

Signature:



Date: 22.01.02