TELEPHONE: 00 44 (0) 1473 277300
FAX: 00 44 (0) 1743 277301

CRANE FLUID SYSTEMS

NACTON ROAD . IPSWICH . SUFFOLK . IP3 9QH

DECLARATION OF CONFORMITY

The Pressure Equipment Directive 97/23/EC
The Pressure Equipment Regulations 1999 No. 2001

Reference No: D151/D237/001

Description of Pressure Equipment:

Bronze Gate Valves – 8, 10, 15, 20, 25, 32, 40, 50, 65, 80 and 100mm – Rated PN20

Service Limitations:

For use on Group 2 Gases and Group 1 & 2 Liquids

Conformity Assessment Procedure Followed:

8 – 50mm	Article 3 Para 3 (Sound Engineering Practice)
65 – 100mm	Module A

Name and Address of the Notified Body monitoring the Manufacturers Quality System:

British Standards Institution
Maylands Avenue
Hemel Hempstead
Hertfordshire
HP2 4SQ

References to Harmonised Standards used

BS EN 1982 (CC491K) 1999

References to other Technical Standards and Specifications used

BS21 1985 *ANSI B1.20.1 1983* *BS6755 Part 1 1986*

BS5154 1985

Authorised on behalf of Crane Fluid Systems

Name: I Wilson

Title: Engineering and Quality Director

Signature: 

Date: 22.01.02