

CRANE

FLUID SYSTEMS

NACTON ROAD

IPSWICH

SUFFOLK

IP3 9QH

DECLARATION OF CONFORMITY
The Pressure Equipment Directive 97/23/EC
The Pressure Equipment Regulations 1999 No. 2001

Reference No: DM160/001

Description of Pressure Equipment:

Bronze Gate Valves – 20, 25, 32, 40, 50, 65 and 80mm – Rated PN16

Service Limitations:

For use on Group 2 Gases and Group 1 & 2 Liquids

Conformity Assessment Procedure Followed:

20 – 50 mm	Article 3 Para 3 (Sound Engineering Practice)
65 & 80mm	Module A

Name and Address of the Notified Body monitoring the Manufacturers Quality System:

British Standards Institution
Maylands Avenue
Hemel Hempstead
Hertfordshire
HP2 4SQ

References to Harmonised Standards used

BS EN 1982 (CC491K) 1999

References to other Technical Standards and Specifications used

BS6755 Part 1 1986 BS5154 1985 BS4504 Section 3.3 1989

Authorised on behalf of Crane Fluid Systems

Name: I Wilson

Title: Engineering and Quality Director

Signature: 

Date: 22.01.02