

CRANE

FLUID SYSTEMS

NACTON ROAD

IPSWICH

SUFFOLK

IP3 9QH

DECLARATION OF CONFORMITY
The Pressure Equipment Directive 97/23/EC
The Pressure Equipment Regulations 1999 No. 2001

Reference No: F493/001

Description of Pressure Equipment:

*Cast Iron Swing Check Valves – 50, 65, 80, 100, 125, 150, 200, 250 and 300mm –
Rated PN13.8*

Service Limitations:

For use on Group 2 Gases and Group 1 & 2 Liquids

Conformity Assessment Procedure Followed:

50 - 65mm	Article 3 Para 3 (Sound Engineering Practice)
80 – 125mm	Module A
150 – 300mm	Module E1

Name and Address of the Notified Body monitoring the Manufacturers Quality System:

British Standards Institution
Maylands Avenue
Hemel Hempstead
Hertfordshire
HP2 4SQ

References to Harmonised Standards used

References to other Technical Standards and Specifications used

ANSI B16.1 1998 BS6755 Part 1 1986 BS5153 1986 (1991) Withdrawn

BS EN 1561 EN-GJL-250 (Modified UTS 220 – 320 N/mm²) 1997

PMA03 PMS510

Authorised on behalf of Crane Fluid Systems

Name: I Wilson

Title: Engineering and Quality Director

Signature:



Date: 02.02.02