

**CRANE**

**FLUID SYSTEMS**

NACTON ROAD

IPSWICH

SUFFOLK

IP3 9QH

**DECLARATION OF CONFORMITY**  
The Pressure Equipment Directive 97/23/EC  
The Pressure Equipment Regulations 1999 No. 2001

**Reference No: F54/001**

**Description of Pressure Equipment:**

*Cast Iron Gate Valves – 50, 65, 80, 100, 125, 150, 200, 250 and 300mm – Rated PN13.8*

**Service Limitations:**

*For use on Group 2 Gases and Group 1 & 2 Liquids*

**Conformity Assessment Procedure Followed:**

50mm & 65mm	Article 3 Para 3
80 – 125mm	Module A
150 – 300mm	Module E1

**Name and Address of the Notified Body monitoring the Manufacturers Quality System:**

British Standards Institution  
Maylands Avenue  
Hemel Hempstead  
Hertfordshire  
HP2 4SQ

**References to Harmonised Standards used**

**References to other Technical Standards and Specifications used**

*BS3464 1965 (Withdrawn)      BS6755 Part 1 1986      BS10 1962*  
*BS EN 1561 EN-GJL-250 (Modified UTS 220 – 320 N/mm<sup>2</sup>) 1997*  
*PMA02      PMA03      PMS723      PMS725*

**Authorised on behalf of Crane Fluid Systems**

Name: I Wilson

Title: Engineering and Quality Director

Signature:



Date: 02.02.02