


Project: Gripple Clamp
Client: Gripple Ltd
Client's Order No: I3879
Inspection Date:
First: 14 / 01 / 2010

Certificate No: COV1019001
Office: Sheffield
Date: 05 / 01 / 2010
Order Status: Complete
Final: 14 / 01 / 2010

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend the premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results

TEST CONFIGURATION



M Cobb *16/2/10*
 Surveyor of Lloyd's Register

Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Results		
Pipe Size Ø 21	7x7 (6/1)	0 - 45 kg 0 - 100 lbs	225 kg 495 lbs	452 kg 994 lbs	392 kg 862 lbs	397 kg 873 lbs

Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Results		
Pipe Size Ø 76	7x7 (6/1)	0 - 45 kg 0 - 100 lbs	225 kg 495 lbs	410 kg 902 lbs	358 kg 787 lbs	397 kg 873 lbs