

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 165a

Industrial Door Engineering Ltd

Product Name	Door Type	Max Height(m)	Max Width (m)	Max Area(m ²)	Fire Resistance (min) BS476: Part 22 Integrity	Fire Resistance (min) BS476: Part 22 Insulation	Reliability (self closing durability Ref: LPS 1056 Clause 3.6)	LPCB Ref No.
Sentry	Rolling shutter	7.0	7.0	49.0	240	0	No performance determined	165a/01
Sentry 2	Rolling shutter	7.0	7.0	49.0	120	0	No performance determined	165a/02
Sentry 1 Compact	Rolling shutter	2.20	3.40	7.48	60	0	No performance determined	165a/03
Sentry 1	Rolling shutter	2.20	2.20	4.84	60	0	No performance determined	165a/04

Notes:

1. LPCB Ref No. 165a/03 – Sentry 1 Compact rolling shutter can be fitted with either the flat or curved lath.
2. Industrial Door Engineering Limited are also Certified for the installation of fire rated Sentry rolling shutter against the requirements of LPS 1271.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: T Baker

Page 2 of 2

Date of Issue 24 September 2009

Issue No. 12

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE global Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.