



Specification
Trench Heating

Specification
Trench Heating

Specification
Trench Heating

- The trench heating cases shall be constructed from A2 Grade stainless steel.* They shall be supplied as a complete made up unit with a copper pipe aluminium fin coil, aluminium edge trim and matching aluminium grille (other grille finishes including wood and stainless steel are available). The unit shall be covered by a 10 year corrosion warranty.
- The unit shall include stainless steel flexible connectors and valves (selected units include thermostatic valves), include levelling feet, and protective covers for use whilst on site.
- Fanned units shall use 12v DC EC motors with an energy consumption not exceeding 7w per linear metre, driving balanced tangential fans. They shall include low temperature cut - outs and be controlled with advanced electronic controls.
- Cooling units, or units for wet conditions, will be supplied with fitted integral drain spigots.
- Outputs will be fully tested in accordance with EN 442.

*With the exception of the T50 which has an extruded aluminium trough.